

Declaration of conformity to EC regulations for CE-marking:

73/23/EEC low voltage directive

89/336/EEC EMC directive

2000/55/EC energy efficiency directive

issue: December 1st, 2006

Replace: March 17th, 2006

QT-25-09

We declare that the below mentioned products are tested and comply with the requirements for CE marking:

In detail, these products were tested according to the following standards:

- EN 61347-2-3** General and safety requirements for A.C.-supplied electronic ballasts for fluorescent lamps.
- EN 60929** Performance requirements for A.C.-supplied electronic ballasts for tubular fluorescent lamps.
- EN 55015** Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment.
- EN 61000-3-2** Electromagnetic compatibility: Limits for harmonic current emissions.
- EN 61000-3-3** Electromagnetic compatibility: Limitation of voltage fluctuations and flicker in low voltage supply systems.
- EN 61547** EMC immunity requirements for equipment for general lighting purposes.
- EN 50294** Measurement method of total input power of ballast-lamp circuits.


ECG type	Mark licence No.:	
	ENEC	EMC
QTP5 1x14-35	40008802	40000036
QTP5 1x24-39	40008802	40000036
QTP5 1x49	40008802	40000036
QTP5 1x54	40008802	40000036
QTP5 1x80	40008802	40000036
QTP5 2x14-35	40008802	40000036
QTP5 2x24-39	40008802	40000036
QTP5 2x49	40008802	40000036
QTP5 2x54	40008802	40000036

Radio disturbance has been tested in a reference luminaire
Products are 100% tested on functioning and safety during manufacturing.

Development Department



Quality Assurance



OSRAM GmbH, Hellabrunner Str. 1, D-81543 München